



Chloro Tech
EQUIPMENTS PVT. LTD.

Electrical Drum Change Over



Office/Factory : Plot No. 305/308 & 309, Chlor House, Ichhapore G.I.D.C. Estate, Near ONGC, Bhatpore Road, SURAT – 394510, (GUJARAT) INDIA.

Ph. (O/F) 0261 – 6531601, 2841601/03 **Fax:** 0261 - 2841602

Email: chlorotech_cl2@yahoo.co.in, ctepl.cl2@gmail.com **Website:** www.chlorotech.in

Electrical Regulating Valve and Automatic Drum

Data Sheet of Valve	
Type	Ball Valve (3 Way Type)
Inlet connection	T - Port
Size	3 / 4 "
Body	CS
Ball	Monel
Sheat	PTFE
Shaft	Monel
End Connection	Screw End
Bore	Full
Make of Valve	AUDCO

* Actuator *	
Model	Qt3
Rated Output Torque Kg m	3
Operation Speed sec/90	18
Switching Frequency Operation/hr	
(A) Short Time	: 2000
(B) Normal	: 1200
Weight	11 Kg
Degree Of Protection	IP 65 / IP 67
Area Of Operation	Safe
Motor Type	Non Blocking A.C. Motor
Supply Std.	220 V AC 50 Hz Single Phase
Supply optional	110 V AC 50 Hz Single Phase
Nominal Current	150 m A
Class Of Insulation	F
Embient Temperature C	45

Data Sheet of Motor	
Type	Non blocking A.C. Synchronous motor
Supply	220 VAC 50/60 Hz 1 Phase
Insulation Class	B
Actuator / Panel mounted Positioner	PP 300 provided
Input for positioner from controller	4 – 20 mA