



Chloro Tech
EQUIPMENTS PVT. LTD.

Motorized Operated Valve



Office/Factory : Plot No. 305/308 & 309, Chlor House, Ichhapore G.I.D.C. Estate, Near ONGC, Bhatpore Road, SURAT – 394510, (GUJARAT) INDIA.

Ph. (O/F) 0261 – 6531601, 2841601/03 **Fax:** 0261 - 2841602

Email: chlorotech_cl2@yahoo.co.in, ctepl.cl2@gmail.com **Website:** www.chlorotech.in

Technical details for Isolation Valve with Motor for Chlorine Gas Line

Body	CS
Ball	Monal
Steam	Monal
Seat	Teflon
Type	Flange End as per ANSI-B-16.5

Motorized Valve

Type	Ball Valve
Valve Size	3/4"
Media	Chlorine Gas (Dry)
Port Size	Full Bore
End Connection	Flange End as per ANSI-B-16.5
Body Material	C.S.
Plug Material	Monal
Seat Material	PTFE
Test Pressure	40 Kg/Cm2
Make	AUDCO

Actuator

Model	Qt3
Rated Output Torque Kg m	3
Operation Speed sec/90	18
Switching Frequency Operation/hr	
(A) Short Time	2000
(B) Normal	1200
Weight	11 Kg
Degree Of Protection	IP 65 / IP 67
Area Of Operation	Safe
Motor Type	Non Blocking A.C. Motor
Supply Std.	220 V AC 50 Hz Single Phase
Supply optional	110 V AC 50 Hz Single Phase
Nominal Current	150 m A
Class Of Insulation	F
Embient Temperature C	45